

# **Town of South Kingstown**

## **Pool & Hot Tub Inspection Requirements**

The following is a summary of the inspection requirements for the Town of South Kingstown.

- All inspections must be coordinated with the Building Inspectors Office at least twenty four (24) hours in advance.
- Electrical Inspections are done on Monday, Wednesday, & Friday. All other inspections are done any day (Monday through Friday).
- The Building Permit DOES NOT cover any electrical, plumbing, or mechanical work. This requires separate permits, which must be obtained at the Building Inspectors Office.
- Failure on the part of the owner or contractor to notify the Building Inspectors Office for a required inspection will result in a STOP WORK ORDER that may cause delay in construction.
- The Building Inspector will affix a sticker approving the inspection or leave a field correction notice pointing out any deficiencies, which will require re-inspection prior to proceeding.

### **Inspections for Inground Pools:**

1. Rebar & rebar bonding (Prior to pouring concrete or spraying gunite)
2. Metal wall sections, metallic equipment, niche shell & fixture bond (prior to covering)
3. Niche shell bond jumper & encapsulating compound (prior to filling pool w/water NEC 680.23B2)
4. Perimeter surface bond (prior to covering NEC 680.26B2)
5. Electric trenches (when conduits or approved cables are in place and prior to backfilling)
6. Final inspection for use and occupancy (prior to use of the pool)

### **Inspections for Above Ground Pools:**

1. Pool bond and perimeter surface bond (prior to covering NEC 680.26B2)
2. Electric trenches (when conduits or approved cables are in place and prior to backfilling)
3. Final inspection for use and occupancy (prior to use of the pool)

### **Inspections for Hot Tubs:**

1. Perimeter surface bond (prior to covering NEC 680.26B2)
2. Electric trenches (when conduits or approved cables are in place and prior to backfilling)
3. Final inspection for use and occupancy (prior to use of the hot tub)

If there are any questions pertaining to the inspection procedures or inspection results, please contact the Building Inspector's Office at (401)-789-9331 ext. 1225.