

**Paula McEvoy, PE**  
**Director of Engineering, NY Division**

**Suez Water New York Inc.**  
360 West Nyack Road  
West Nyack, NY 10994  
TEL 845-620-3324



December 11, 2018

Scot Hallberg  
235 Main Street  
Wakefield, RI 02879

*Re: Will Serve – Hillside Condos*  
Wakefield, RI 02879

Dear Mr. Hallberg;

This is to advise you that water service can currently be made available to the proposed 19 unit condo development located on Tower Hill Road/Kelly Way, using a projected max day demand of 9500 gpd, and fire flow of 1000 gpm subject to the below conditions. The proposed development will be fed by a metered connection at Kelly Way and the water main, services and hydrants will be privately owned and maintained.

- 1) Prior to the installation of any services or the extension of any mains, hydraulic data pertinent to the project must be provided to us, for our Engineering Department review and approval.
- 2) If, as a result of such review, it is decided that any extension of mains or pipes or modification of other facilities is required in order to meet the hydraulic needs of the project, those mains or facilities will be installed or extended by you in accordance with the terms and conditions of this Company's standard agreements for extensions.
- 3) Service will be provided in accordance with the terms and conditions set forth in the Company's filed Tariff, as amended or modified from time to time.
- 4) Water mains shall be laid in accordance with the Recommended Standards for Water Works (a.k.a. Ten State Standards).

This willingness to serve letter is contingent upon SUEZ Water Rhode Island Inc. (SWRI) having County, State and Federal regulatory authorization to provide the requested water service and is valid for nine (9) months from the date of issuance. If the main installation/extension or service installation is not completed and approved by the Department of Health within nine (9) months from the date this letter is issued, this willingness to serve letter will expire, and it will be necessary for you to request a new willingness to serve letter.

Please contact me at 845-620-3324 if you need additional information.

Very truly yours,

*Paula L McEvoy*

Paula L McEvoy

cc: Chris Jacobs, Manager – SWRI